

Kiwa GmbH, Gutenbergstraße 29, D-48268 Greven

Estil Guru S.L.L.
P.I. L'Altet C/ Casa D'osca 8
46870 Ontinyent (Valencia)
SPAIN

Kiwa GmbH
TBU
Gutenbergstraße 29
D-48268 Greven

T: +49 (0) 2571 9872 – 0
F: +49 (0) 2571 9872 – 99
E: infokiwagreven@kiwa.de

www.kiwa.de

Project: -

Factory: -

Date of order 20.02.2020

Testrequest: 1.Determination of reaction to fire according to ETAG 022-2 (11.2010)
2.Determination of water vapour permeability according to ETAG 022-2 (11.2010)
3.Determination of water tightness according to ETAG 022-2 (11.2010)
4.Determination of resistance to temperature according to ETAG 022-2 (11.2010)
5.Determination of resistance to alkalinity according to DIN EN 1847 (04.2010)

Material: Sealing tape (white) consisting of EVA copolymer film with PP / PE nonwoven fleece on the external faces and a extruded butyl adhesive tape
a) **SAFE BAND**


Number of samples: 3 rolls

Sampling: -


Sample delivery date: 16.03.2020, 14.10.2020

Test duration: 20.02.2020 – 13.01.2021

Greven, 13.01.2021


i.V. Dr.-Ing. Melanie Strutz
(deputy head of test laboratory)




i.A. Hendrik Lösing
(staff of test laboratory)

Test results apply exclusively to the specimen submitted. Without written permission of the testing laboratory it is not allowed to publish parts of the report.

a) information by customer

Geschäftsführer: Prof. Dr. Roland Hüttl

Amtsgericht Hamburg, HRB 130568, St.Nr.: 46/736/03268



1. Determination of reaction to fire

The sealing kit has been tested according to EN ISO 11925 -2 (07.2020) with a single-flame source test. The test was carried out by an external laboratory. Detailed test parameters are shown in the test report

PB-Hoch-201122 from 30.11.2020 and the classification report KB-Hoch-201123 from 30.11.2020

Result: Classification E according to EN 13501-1 (2018)

2. Determination of water vapour permeability

Test parameters:

Climatic parameter: A

Temperature: 23°C

Humidity: 50 % / 0 %


Mean air pressure: 1014 hPa

Exposed specimen area: 0,005 m²

Number of specimens: 5 specimen

Duration: The water vapour quantities which diffused the specimens until a steady state had been reached were determined, i.e. until a constant diffusion stream through the specimens had occurred. A check was made by determining the empiric correlation coefficient r .

Test arrangement:



Results:

Tab.1: Test results water vapour permeability

Specimen No.	water vapour transmission stream per unit area g kg/(m ² s)	water vapour transmission coefficient w_p kg/(m ² s Pa)	water vapour transmission ratio μ —	thickness equivalent to water vapour transmission s_d m	mean thickness of specimen at 20 kPa d mm	mass per unit area — g/ m ²
1	5,69E-08	4,06E-11	7098	4,80	0,676	289
2	4,12E-08	2,94E-11	9585	6,63	0,692	289
3	4,89E-08	3,49E-11	8257	5,58	0,676	290
4	4,21E-08	3,00E-11	9695	6,50	0,670	289
5	7,81E-08	5,59E-11	5103	3,49	0,684	289
Mean	5,34E-08	3,82E-11	7947	5,40	0,680	289
Standard deviation	1,52E-08	1,09E-11	1913,5	1,300	0,0085	0,7
Coefficient of variation in %	28,4	28,5	24,1	24,1	1,3	0,2

3. Determination of water tightness

Standard: DIN EN 1928 (07.2000), Procedure B
 Test pressure: 150 kPa for 24h
 Test procedure: The determination of water tightness was performed according to DIN EN 1928 procedure B. The specimens were exposed to water for 24h at a constant pressure of 150 kPa. The test is passed when all specimens are watertight after the exposure.
 Test date: 22 September 2020/ 23 September 2020/ 24 September 2020

Result: All 3 specimens were watertight after exposure at 150 kPa for 24h.

4. Determination of resistance to temperature

Standard: DIN EN 12311-2 (11.2013); DIN EN 1296 (03.2001)
 Number of samples: 5 x Safeband MD, per storage
 5 x Safeband CMD, per storage

storage temperature storage: (70°C)
 reference: % r.h.

test date:

test device: Zwick Z050

Remark: LE 60 mm instead of 120 mm due to the fact of a max. specimen width of 10 cm in CMD direction.

Results:

Tab.2: results of the reference samples

Sample no.	Reference MD		Reference CMD	
	Fm N	elongation %	Fm N	elongation %
1	383,19	45,24	356,15	67,10
2	367,81	42,97	366,65	68,78
3	36,50	39,60	356,11	69,07
4	377,49	39,62	361,76	66,67
5	354,49	39,64	367,78	65,50
mean	370,44	41,41	361,69	67,42
Standard deviation	10,99	2,59	5,56	1,49
Coeff. of var.[%]	2,97	6,24	1,54	2,21



Test report no. 2.1/14641/0286.0.1-2020e

Remark: LE 60 mm instead of 120 mm due to the fact of a max. specimen width of 10 cm in CMD direction.

Tab.3: results of the temperature storage

Sample no.	temperature MD		temperature CMD	
	Fm N	elongation %	Fm N	elongation %
1	325,97	31,84	287,33	59,47
2	318,62	34,47	269,68	49,68
3	351,06	35,63	282,83	53,63
4	327,09	32,87	267,62	55,17
5	329,25	36,04	271,59	57,80
mean	330,40	34,17	275,8	55,15
Standard deviation	12,22	1,79	8,72	3,81
Coeff. of var.[%]	3,70	5,24	3,16	6,90

The results relate to the fracture between nonwoven/membrane

5. Determination of resistance to alkalinity

Standard: DIN EN 12311-2 (11.2013);
DIN EN 1847 (04.2010) ,80°C storage in calcium hydroxid for 4 weeks

Samples: 5 x Safeband MD
5 x Safeband CMD

Storage: 19.08.2020 – 16.09.2020 Test date:

Test device: Zwick Z050

Remark: LE 60 mm instead of 120 mm due to the fact of a max. specimen width of 10 cm in CMD direction.

Tab. 4: Results of the resistance to alkalinity

Sample no.	alkalinity MD		alkalinity CMD	
	Fm N	elongation %	Fm N	elongation %
1	156,52	52,67	139,78	65,21
2	160,95	42,81	142,19	65,27
3	157,87	51,50	136,74	67,27
4	153,94	47,07	140,07	65,88
5	153,71	48,48	140,32	62,71
mean	156,60	48,51	139,82	65,27
Standard deviation	3,00	3,90	1,96	1,65
Coeff. of var.[%]	1,91	8,04	1,40	2,53